

OFFICE OF THE DISTRICT FIRE OFFICER  
SARJAPUR ROAD FIRE STATION  
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

SI.No. 38/DFO/SRFS/Bng/FSR/2025

OFFICE OF THE DISTRICT FIRE OFFICER  
Karnataka State Fire & Emergency Services  
Sarjapura Road Fire Station  
Bangaluru-560 035.

"Annexure-2"

To,  
The Secretary,  
Ashok Group Of Institutions(KBC Trust),  
Ashok International Public School(CBSE)  
Ashok Composite PU College,  
#42&45, Kammagondahalli, Jalahalli West  
Bengaluru-560 015.

Sir,

**Sub :** Issue of "Fire Safety Compliance report" with respect to fire prevention, fire fighting and evacuation measures maintained at **"M/s.Ashok Group Of Institutions(KBC Trust), Ashok International Public School(CBSE) & Ashok Composite PU.College, # 42 & 45, Kammagondahalli, Jalahalli West Bengaluru-560 015.**


**Ref :** 01) This office FSR No. 25/FSO/SRFS/Bng/FSR/2023 Date:02 -06-2023.  
02) Your request letter dated:-20-05-2025.,

<<<>>>

With reference to the above cited subject, as per ref a conditional Fire Safety Recommendation was issued to the premises **"M/s.Ashok Group Of Institutions(KBC Trust), Ashok International Public School(CBSE) & Ashok Composite PU College, # 42 & 45, Kammagondahalli, Jalahalli West Bengaluru-560 015.** with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of **"M/s. Ashok International Public School (CBSE)" & "Ashok Composite PU College"** had requested for the fire safety compliance report from our department. In this regard the Fire Station officer, Sarjapur road Fire Station, Bengaluru was inspected on 02-06-2025 and submitted the report to issue fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to **"M/s.Ashok Group Of Institutions(KBC Trust), Ashok International Public School(CBSE) & Ashok Composite PU College, # 42 & 45, Kammagondahalli, Jalahalli West Bengaluru-560 015.** Subject to proper maintenance of fire fighting installations in the good working conditions, one generator of Suitable capacity to supply alternative power for staircase lighting, corridor lighting etc., in the event of failure of electricity supply in the building and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report "This report is valid up to only one year from the date of issue and is renewable without fail."



PRINCIPAL  
ASHOK INTERNATIONAL PUBLIC SCHOOL  
Affiliated to CBSE  
Bangalore-560 015

Yours faithfully,

DISTRICT FIRE OFFICER  
Sarjapura Road Fire Station  
Bangaluru-560 035